

Chelsea Lantern Installation

Mounting Height: 3-6 Metres



Units 4&5, Bear Court
Roentgen Road
Basingstoke
RG24 8QT
01256 308467
info@acrospire.co

INSTALLATION STEPS

NOTE: - This lantern must be earthed. Electrical supply must be isolated prior to installation or any maintenance. Risk of electric shock from 230V incoming supply

1. This lantern is always supplied pre-wired. There should be no requirement to open the fitting.
2. Feed the cable into the column and lower the fitting onto the column / bracket (noting the 'Roadside' orientation)
3. Tighten alternately each of the four grub screws to 10Nm.
4. Switch on the main's supply. (If a photocell is fitted, the lantern will initially illuminate but should turn off within 30 seconds).

DO NOT STARE INTO LED SOURCE

The luminaire should be positioned so that prolonged staring into the luminaire at a distance of less than 1.87 M is not expected.

SPECIFICATION

Height	590mm
Width at Widest Point	475mm
Tightness Rating	Optic IP66 Gear Enclosure IP65
IK Rating	IK10
Mounting Arrangement	76mm Post Top
Input Current	250mA-850mA



CLEANING

The optic assembly is factory sealed therefore only the exterior surface needs to be cleaned. A damp lint free cloth should be used. Cleaning products should be avoided as they may cause damage to the painted surface.

