

# StreetCare Lantern Installation

Mounting Height: 4-6 Metres



Units 4&5, Bear Court  
Roentgen Road  
Basingstoke  
RG24 8QT  
01256 308467  
[info@acrospire.co](mailto:info@acrospire.co)

## INSTALLATION STEPS

**NOTE:** - This lantern must be earthed. Electrical supply must be isolated prior to installation or any maintenance. Risk of electric shock from 230V incoming supply

1. This lantern is always supplied pre-wired. There should be no requirement to open the fitting.
2. Feed the cable into the column and lower the fitting onto the column / bracket (noting the 'Roadside' orientation)
3. Tighten alternately each of the four grub screws to 10Nm.
4. Switch on the main's supply. (If a photocell is fitted, the lantern will initially illuminate but should turn off within 30 seconds).

**DO NOT STARE INTO LED SOURCE**

The luminaire should be positioned so that prolonged staring into the luminaire at a distance of less than 1.87 M is not expected.

SPECIFICATION	
Height	650mm
Width	270mm
Tightness Rating	Optic IP66 Gear Enclosure IP65
IK Rating	IK10++
Mounting Arrangement	76mm Post Top
Input Current	250mA-850mA



## CLEANING

The optic assembly is factory sealed therefore only the exterior surface needs to be cleaned. A damp lint free cloth should be used. Cleaning products should be avoided as they may cause damage to the painted surface.

